



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

100 East Eleventh Street

Saint Paul, MN 55101

Telephone: 651-228-6230

Facsimile: 651-228-6241

CODE ENFORCEMENT POLICY # 7-5

TO: All Inspection Staff

FROM: Steve Zaccard, Fire Marshal

SUBJECT: **DISPENSING GASOLINE FROM ABOVEGROUND TANKS**

CODE REFERENCE: MSFC 2206.2.7 AMMENDMENT

“THIS POLICY IS TO SERVE AS A GUIDE FOR YOUR ENFORCEMENT. EXCEPTIONS TO THIS POLICY SHALL BE APPROVED BY THE FIRE MARSHAL THROUGH YOUR SUPERVISOR”.

When approved by the fire chief, Class I and Class II liquids are permitted to be dispensed into the fuel tank of a motor vehicle from aboveground tanks when such tanks are installed inside special enclosures in accordance with MSFC 2206.2.6, from protected tanks conforming with section 3404.2.9.6 or when such dispensing systems meet the requirements of section 2206.2.7.1 through 2206.2.7.1.10.

The dispensing of gasoline and other Class I liquids from above ground tanks into vehicles is prohibited in Saint Paul, except when dispensed from UL 2085 or similar listed fire resistive tanks.

The capacity of the listed fire resistive tank must be approved by the Fire Marshal.

Issued: 3/21/06